

Case study: Bayesian analysis of a flow meter calibration problem


Gertjan Kok
VSL, the Netherlands

G J P Kok, A M H van der Veen, P M Harris, I M Smith and C. Elster (2015)
*Bayesian analysis of a flow meter calibration problem, **Metrologia**, 52, 400-405*


BIPM Workshop on Measurement Uncertainty
Paris, 15-16 June 2015

Outline

- Bayesian analysis of flow meter calibration problem
 - An example of a normal linear regression problem
- Treatment of different prior knowledge
 - About flow meter calibration curve
 - About repeatability of flow meter
- Comparison with classical ordinary least squares (OLS) approach



Background




- Flow meter measures the volume of fluid flowing through the meter per unit of time, e.g. reported in L min^{-1}
- High-quality meter will have an electrical pulse output such that each pulse corresponds to a fixed volume flowing through the meter
- Frequency of the pulse output is proportional to flow rate q , and the proportionality constant is the K-factor k
- A calibration involves determining the K-factor for several known flow rates, and fitting a curve to the calibration data
- That calibration curve is used to provide an estimate of the K-factor at any flow rate within the measurement range of the device

Prior knowledge regarding flow meter calibration

- Specified K-factor by manufacturer (constant)
-> correct within 1 %
- Calibration curve of previous calibration
-> correct within 0.1 %
- Typical variation in curve
-> maximum and minimum values differ by less than 0.2 %
- Information on repeatability specified by manufacturer
-> estimate of 0.025 % with degree of belief v_0

Data and some of the prior knowledge



Statistical model

- Calibration data

$$(q_i, k_i), \quad i = 1, \dots, n$$

- Calibration curve

$$f_{\beta}(q) = \beta_1 + \beta_2 / q + \beta_3 q + \beta_4 q^2 + \beta_5 q^3$$

- Statistical model

$$k_i = f_{\beta}(q_i) + \varepsilon_i, \quad \varepsilon_i \sim N(0, \sigma^2)$$


- Normal linear regression problem with parameters β and σ^2

Bayesian analysis

Prior knowledge


Data &
statistical model

Posterior knowledge




Prior distribution

“+”




Likelihood
function

Bayes
theorem




Posterior distribution

Prior distribution for curve parameters β




Prior distribution for repeatability σ

Inverse-Gamma($\nu_0 / 2, \nu_0 \sigma_0^2 / 2$) with $\sigma_0 = 0.025 \%$




Prior and posterior distributions for σ

$\nu_0 = 1$





$\nu_0 = n$



- As $\nu_0 \rightarrow 0$, the data dominates (as represented by the OLS estimate σ_{OLS})
- As $\nu_0 \rightarrow \infty$, the prior dominates (as represented by the prior estimate σ_0)


Estimate of the calibration curve

Calibration curve $f_{\beta^{\wedge}}(q)$, point-wise 95 % credible intervals, and constraints on calibration curve




Standardized residuals
 $(k_i - f_{\beta^{\wedge}}(q_i)) / \sigma^{\wedge}$

Prior and posterior distribution for K-factor for particular flow rate



Prior distribution
(appr.: 13.144 to 13.171)



Posterior distribution
(appr.: 13.157 to 13.159)




Numerical results and comparison

Approach	$k_{\beta}(q_{\min}) \text{ (L}^{-1}\text{)}$	$k_{\beta}(q_{\text{mid}}) \text{ (L}^{-1}\text{)}$	$k_{\beta}(q_{\max}) \text{ (L}^{-1}\text{)}$
OLS (σ unknown)	13.15947 (56)	13.15812 (33)	13.15841 (54)
BAY ($\nu_0 = 1$)	13.15947 (59)	13.15812 (35)	13.15841 (57)
BAY ($\nu_0 = m$)	13.15947 (111)	13.15812 (65)	13.15841 (107)
OLS ($\sigma = \sigma_0$)	13.15947 (142)	13.15812 (83)	13.15841 (137)

- Estimates of K-factors are equal for all statistical approaches
- Standard uncertainties of K-factors vary depending on the weight given to the prior information on the repeatability

Influence of prior information

Distributions for $f_{\beta}(q_{\min})$ as constraint relating to previous calibration becomes tighter



Numerical results and comparison

(case: more informative prior knowledge on calibration curve)

Approach	$k_{\beta}(q_{\min}) \text{ (L}^{-1}\text{)}$	$k_{\beta}(q_{\text{mid}}) \text{ (L}^{-1}\text{)}$	$k_{\beta}(q_{\max}) \text{ (L}^{-1}\text{)}$
OLS (σ unknown)	13.159 47 (56)	13.158 12 (33)	13.158 41 (54)
BAY ($\nu_0 = 1$)	13.158 97 (35)	13.158 08 (35)	13.158 39 (57)

- Estimates of K-factors are different, especially for smallest flow rate
- Standard uncertainties of K-factor at smallest flow rate becomes smaller, as prior knowledge ‘actively adds information’ in this case
- Standard uncertainties of K-factors at other flow rates are almost identical to the values before

Final remarks

- Numerical algorithm is quite straightforward and only uses methods similar to GUM Supplement 1.
- Treatment does not answer questions about whether the flow meter ‘conforms to specifications’ about its repeatability and calibration curve
 - By interpreting those ‘specifications’ as prior knowledge, the flow meter is forced to conform!
- Use of ‘strict’ constraints leads to posterior distributions that are truncated at the boundaries of the constraints
 - Alternative forms of prior distributions, which associate small probabilities with ‘infeasible’ calibration curves, might be considered to be more realistic but are more difficult to cope with numerically.

Conclusion and acknowledgment

- Bayesian analysis permits both prior information about the flow meter and observed data to be used.
- In contrast, Ordinary Least Squares only treats the extreme cases where any of the unknowns (regression parameters β and variance of the data σ^2) is either completely known or unknown.

This work has been funded by the European Metrology Research Program (EMRP) project ***NEW 04 Novel mathematical and statistical approaches to uncertainty evaluation***.

The EMRP is jointly funded by the EMRP participating countries within EURAMET (European Association of National Metrology Institutes) and the European Union.